

Dr. Babasaheb Ambedkar Technological University ,

P.O. LONERE - 402 103 , Tal. Mangaon , Dist. Raigad

27 NOV 2019

Our Ref No. :DBATU/Store/EED/UPS with Battery /2019/ 3644
Quotation For 5.2KVA UPS with Battery
Date of Opening : 17/12/2019

Date : 25/11/2019
Due On : 16/12/2019
Time : 03.00 PM

To,

O/C

Sub : QUOTATION FOR THE SUPPLY OF STORES

Dear Sir ,

Your quotation for the items listed overleaf , may please be submitted to the under signed, so as to reach this Office not later than 16/12/2019

While submitting your quotation, the following procedure may please be observed and other points borne in mind.

01. The maker's name must be specified.
02. The "Terms and Conditions" for supply and delivery of stores, should be clearly indicated in the quotation, stating whether rates are, inclusive of all taxes, Packing and forwarding charges Freight charges etc. or not, However rates offered as including all taxes will be more welcome.
03. If packing and forwarding charges are to be charged separately, it should be so clearly stated in your quotation.
04. Please mention clearly whether consignment would be Ex-Godown, Ex-Shop, of F.O.R. dispatching stations. Preferably terms offered as "Delivery of consignment of stores, on F.O.R."
05. Envelope should be clearly marked with our reference No and date of this quotation. It should also be superscripted as per the format given above.
06. The quotation would be opened as per date and timing given above, if desired by you, you may depute an authorized representative with a letter of authority to be present at the time of opening of the quotation at this Office on the aforesaid day, date & time.
07. Your quotation must be valid for a minimum 30 (Thirty) working days from the date of it's opening.
08. Quotation received after the date of opening may not be taken into consideration.
09. Items tendered should confirm to the specification shown in the attached list when and where, full or no specifications are indicated against items in the list. Kindly furnish your full specification in accordance with accepted standards against each item tendered. Where reference to catalogue is made, the relevant catalogues/ Pamphlets/ Literature should accompany the quotation.
10. Your quotation should be for all new items and not for second hand.
11. Please state whether items will be available Ex-Stock. If not the minimum period for delivery, or for supplying the items or stores.
12. Freight or packing and forwarding charges, or any other taxes and duties etc. leviable.

13. It would be appreciated if illustrated catalogues/Literature etc is furnished with the quotation.
14. Expression to as "Complete with standard Equipment" complete with standard accessories "Equipment to" As good as should be avoided. If at all their use is unavoidable then it should be very specifically indicated as to what exactly they mean and what exactly would be supplied under them. Any ambiguity or vagueness should be avoided.
15. For convenience, kindly adopt while quoting the same serial Nos. as given in the list detailed below.
- Thanking You.

Yours faithfully,

Registrar

Dr. Babasaheb Ambedkar Technological University

List Of Items

Sr no.	Details of Equipment/Software	Qty	Make	Rates per Unit	Total
1.	<p>UPS 5.2 KVA</p> <ul style="list-style-type: none"> • Sine Wave UPS • Supports 4 battery 150AH • 24 Month Warranty • Safe for sensitive appliances with Sine wave out-put • Auto over-load, Short Ckt, Under Voltage ,Over Voltage, Under Frequency, Over Frequency handling capacity • Installation and maintenance friendly • MCB for protection from Input mains • Bypass switch for supplying output directly from grid in case of Laboratory UPS fault. • Noiseless Operations with the help of low harmonic distortion 	03 Nos	Microtek Or Similar, Stranded Brand		

	<ul style="list-style-type: none"> • Intuitive Display to easily understand status of mains availability, battery status, input and Output Voltage etc. • Comprehensive protection against short-circuit, reverse polarity, battery over-charge, deep-discharge etc • Adaptive Battery charging control system technology (ABCC) ensures faster battery charging and enhances battery life by around 70% • Supports a wide battery range, i.e. Flat Plate, Tubular & VRLA (SMF) 				
2.	Exide 150AH Tall Tubular battery IT 500	12 nos	Exide		

ok

[Signature]
26/11/2019