



DR. BABASAHEB AMBEDKAR TECHNOLOGICAL UNIVERSITY, LONERE

At. Po. Lonere, Tal. Mangaon, Dist. Raigad 402 103 MS (www.dbatuonline.com)

INVITATION FOR QUOTATION

Our Ref No.: DBATU/Store/Estate/Fire Extinguisher/2020/83

Date: 09/01/2020

Quotation For: Fire Extinguisher

Due On: 22/01/2020

Date of Opening: 23/01/2020

Time: 3.00 pm

To,

Sub: QUOTATION FOR THE SUPPLY OF STORE

Dear Sir,

Your quotation for the items listed overleaf, may please be submitted to the under signed, so as to reach this Office not later than 23/01/2020. While submitting your quotation, the following procedure may please be observed and other points borne in mind.

01. The maker's name must be specified.
02. The "Terms and Conditions" for supply and delivery of stores, should be clearly indicated in the quotation, stating whether rates are, inclusive of all taxes, Packing and forwarding charge,s Freight charges, etc. or not, however rates offered as including all taxes will be more welcome.
03. If packing and forwarding charges are to be charged separately, it should be so clearly stated in your quotation.
04. Please mention clearly whether consignment would be Ex-Godown, Ex-Shop, of F.O.R. dispatching stations. Preferably terms offered as "Delivery of consignment of stores, on F.O.R.
05. Envelope should be clearly marked with our reference No and date of this quotation. It should also be superscripted as per the format given above.
06. The quotation would be opened as per date and timing given above, if desired by you, you may depute an authorized representative with a letter of authority to be present at the time of opening of the quotation at this Office on the aforesaid day, date & time.
07. Your quotation must be valid for a minimum 30 (Thirty) working days from the date of it's opening.
08. Quotation received after the date of opening may not be taken into consideration.
09. Items tendered should confirm to the specification shown in the attached list when and where, full or no specifications are indicated against items in the list. Kindly furnish your full specification in accordance with accepted standards against each item tendered. Where reference to catalogue is made, the relevant catalogues/ Pamphlets/ Literature should accompany the quotation.
10. Your quotation should be for all new items and not for second hand.
11. Please state whether items will be available Ex-Stock. If not the minimum period for delivery, or for supplying the items or stores.
12. It should be clearly stated whether **GST**, Insurance, Freight or packing and forwarding charges, or any other taxes and duties, etc. leviable.

13. It would be appreciated if illustrated catalogues/Literature etc is furnished with the quotation.
14. Expression to as "Complete with standard Equipment" complete with standard accessories "Equipment to" As good as should be avoided. If at all their use is unavoidable then it should be very specifically indicated as to what exactly they mean and what exactly would be supplied under them. Any ambiguity or vagueness should be avoided.
15. For convenience, kindly adopt while quoting the same serial Nos. as given in the list detailed below.

Thanking You.

Yours faithfully,

sd

Registrar

Dr. Babasaheb Ambedkar Technological University, Lonere

List of Items

Sr. No.	Description / Specification	Make	Approx. Qty Req.	Rate per / Each / Unit	Remarks
Fire Extinguisher					
01	<p>Carbon di oxide 2 kgs. Capacity Fire Extinguisher Complete with Bend & Horn confirming IS 15683 with ISI mark (C)</p> <p><u>Generic</u></p> <ul style="list-style-type: none"> Conformity to Standard : IS:15683: 2006 With Latest Amdmnt. Type : Stored Pressure Extinguishing Media : Carbon Dioxide Based Expellant Medium : CO2 Extinguishing Medium <p><u>Constructional</u></p> <ul style="list-style-type: none"> Carbon Dioxide Based Fire Extinguisher Capacity (Kg) : 2 Weight of Filled Portable Fire Extinguisher (Kg) : 8.85 Rechargeable : Yes Color Coding : Red Fire Extinguisher Suitable for electrical Fire : Yes <p><u>Performance</u></p> <ul style="list-style-type: none"> Operating Temperature(C) : -30°C to +55°C Test Pressure /Burst pressure for CO2 type Extinguisher (write NA if no applicable) : Test Pressure - 200.2 Bar /Burst pressure – 250 Bar Discharge Range for Extinguisher (Meters) : >= 2 for Class –A Effective Discharge time for fire Extinguisher, min (Seconds) : 15 Fire Rating for Class –B fire 		35 Nos		

	Extinguisher : 8B				
02	<p>ABC type stored pressured dry powder of 6 kgs. Capacity complete with metal cap confirming IS 15683 with ISI (ABC)</p> <p><u>Generic</u></p> <ul style="list-style-type: none"> • Conformity to Standard IS : 15683:2006 With Latest Amdmnt. • Type : Stored Pressure • Extinguishing Media : Powder Based • Expellant Medium : N2 Based (Stored Pressure) <p><u>Constructional</u></p> <ul style="list-style-type: none"> • Powder Based Extinguishing Media :ABC • Powder Based Fire Extinguisher Capacity (Kg) : 6 • Weight of Filled Portable Fire Extinguisher (Kg) :9 • Rechargeable : Yes • Color Coding : Blue • Fire Extinguisher Suitable for electrical Fire :Yes <p><u>Performance</u></p> <ul style="list-style-type: none"> • Operating Temperature (° C) : -20° C to + 55° C • Test pressure/Burst Pressurire Extinguisher except CO2 :for water/Foam/Powder type re extinguisher Test Pressure >=20 Bar, Burst Pressure >=55 Bar • Discharge Range for Extinguisher (Meters) : >=2 for Class-A • Elective Discharge Time for Fire Extinguisher, Min (Seconds) : 13 • Fire Rating for Class -A Fire Extinguisher : 3A • Fire Rating for Class -B Fire Extinguisher: 34B 	23 Nos			
03	<p>Water Co2 type fire extinguisher of 09 ltr. Capacity, complete with metal cap confirming IS 15683 with ISI mark (W)</p> <p><u>Generic</u></p> <ul style="list-style-type: none"> • Conformity to Standard: IS: 15683:2006 With Latest Amdmnt. • Type : Gas Cartridge Type • Extinguishing Media : Water Based • Expellant Medium : CO2 Cartridge Based <p><u>Constructional</u></p> <ul style="list-style-type: none"> • Foam Based Extinguishing Media: Aqueous Film Forming Foam (AFFF) • Water Based Fire Extinguisher Capacity:9 • Weight of Filled Portable Fire 	05 Nos			

	<p>Extinguisher (Kg):15</p> <ul style="list-style-type: none"> • Rechargeable : Yes • Color Coding :Red • Fire Extinguisher Suitable for Class -A Fire : Yes • Operating Temperature (° C) : +5° C to + 55° C • Test pressure/Burst Pressurire Extinguisher except CO2 :for water/Foam/Powder type re extinguisher Test Pressure >=20 Bar, Burst Pressure >=55 Bar • Test pressure/Burst pressure for CO2 type Extinguisher (write NA if not applicable) : - • Discharge Range for Extinguisher (Meters) : >=2 for Class-A • Eective Discharge Time for Fire Extinguisher, Min (Seconds) :13 • Fire Rating for Class A Fire Extinguisher : 4A 				
04	<p>Fire bucket for stand (FB)</p> <p>Certifications</p> <ul style="list-style-type: none"> • "Conforming to Indian Standard IS 726 : latest (Galvanized Steel Buckets For General Use)" : Yes • ISI Marking : No • CM/L Number : 39861 <p>Test Report Details</p> <ul style="list-style-type: none"> • Test Report to be Submitted to the Buyer on demand : Yes <p>Classification and Size</p> <ul style="list-style-type: none"> • Classification: Standard Quality • Standard Quality Bucket Sizes (mm): 325 • Utility Quality Buckets Sizes (mm) : 325 • Capacity (in Liters) : 9 <p>Material and Thickness</p> <ul style="list-style-type: none"> • Material : "Steel sheets used for the body, bottom and bottom ring shall be either cold-rolled (annealed) quality conforming to IS 513 or hot rolled quality conforming to IS 1079" : Yes • Mild steel rods used in the manufacture of handle shall conform to Grade St 32-0 of IS 1977: Yes • Thickness of Body (mm) 0.63 • Thickness of Bottom (mm): 0.63 • Thickness of Bottom Rings(mm): 0.63 • Thickness of Handle Diameter (minimum) (mm) : 10 • Ear(in mm) for sizes up to 250 mm : 2.5 • Ear(in mm)for sizes 275mm and above : 3.15 		30 Nos		

	<ul style="list-style-type: none"> • Tolerances on dimensions of thickness of steel sheet used for body, bottom and bottom rings shall be as per IS:513:1973 or IS: 1079:1973 whichever is applicable : Yes • Tolerances on ear dimensions shall be as per IS: 1852:1973 : Yes <p>Finishing, Marking and Packing</p> <ul style="list-style-type: none"> • "All parts of the bucket shall be finished smooth and sharp edges rounded off" : Yes • "The buckets after fabrication shall be hot-dip galvanized and the galvanized coating shall be free from blisters, grittiness, stains and bare spots, in accordance with Appendix A of IS : 2629" : Yes • Initials NR in 45 mm letter : Yes • Buckets shall be packed in bundles of six in the case of 325 mm and 350 mm sizes and in bundles of 12 in the case of all other sizes: Yes 				
05	M.S. fire stand for 2 buckets (FBs)		16 Nos		

FORMAT FOR QUOTATION SUBMISSION
(In letterhead of the supplier with seal)

Date: _____

To: _____

Sr. No.	Description of goods (with full Specifications)	Qty.	Unit	Quoted Unit rate in Rs. (Including Ex Factory price, excise duty, packing and forwarding, transportation, insurance, other local costs incidental to delivery and warranty/ guaranty commitments)	Total Price (A)	Sales tax and other taxes payable	
						In %	In figures (B)
Total Cost							

Gross Total Cost (A+B): Rs. _____

We agree to supply the above goods in accordance with the technical specifications for a total contract price of Rs. _____
(Amount in figures) (Rupees _____ amount in words) within the period specified in the Invitation for Quotations.

We confirm that the normal commercial warranty/ guarantee of _____ months shall apply to the offered items and we also confirm to agree with terms and conditions as mentioned in the Invitation Letter.

We hereby certify that we have taken steps to ensure that no person acting for us or on our behalf will engage in bribery.

Signature of Supplier
Name: _____
Address: _____
Contact No: _____