



# Dr. Babasaheb Ambedkar Technological University

(Established by Government of Maharashtra and Governed by Dr. Babasaheb Ambedkar Technological University Act No. XXIX of 2014)

Vidyavihar, Lonere – Raigad 402 103 (Maharashtra)

[www.dbatu.ac.in](http://www.dbatu.ac.in)

02140-275081/212

Department: Procurement & e-Tendering  
DBATU, Lonere

Date: 2<sup>nd</sup> September, 2021

## Corrigendum

**Subject:** Corrigendum regarding revised specification of one item in BoQ.

**Reference:** 1) e-Tender notice DBATU/StorePneT/2021-22/01

2) Tender 2021\_DBATU\_7164731\_1

This is for information to all bidders that following corrigendum/ amendment is being made with respect to reference no.2 that, revised specification are as follows:


Tender Ref. No.: DBATU/Electrical Maintenance/2021/02

Tender ID: 2021\_DBATU\_7164731\_1

BoQ item no.:3

BoQ item no.	Old specification	Revised specification
3	Supplying, erecting & terminating XLPE armoured cable 4 core 120 sq. mm. copper conductor with continuous 8.35 sq. mm. (10 SWG) G.I. earth wire complete erected with glands & lugs, on wall/ trusses/ pole or laid in provided trench, trench/pipe as per university requirements specification no. CB-LT/AL (PWD CSR-18-19) / Rate Analysis	Supplying, erecting & terminating XLPE armoured cable 4 core <b>95 sq. mm.</b> copper conductor with continuous 8.35 sq. mm. (10 SWG) G.I. earth wire complete erected with glands & lugs, on wall/ trusses/ pole or laid in provided trench, trench/pipe as per university requirements specification no. CB-LT/AL (PWD CSR-18-19) / Rate Analysis


Other terms & conditions remain the same.

  
Professor in-charge

Procurement & e-Tendering



  
Registrar

  
H R Wushikar