

## INVITATION FOR QUOTATION

Our Ref No. : DBATU/Store/Street light/2024/ 4706

Date: 09/12/2024

Quotation For: Supply of LED Street/ Flood light and service wire

Due On: 23/12/2024

Date of Opening: 24/12/2024

Time: 11.00 am

12 DEC 2024

To,

### Sub: QUOTATION FOR THE SUPPLY OF STORE

Dear Sir,

Your quotation for the items listed overleaf, may please be submitted to the under signed, so as to reach this Office not later than 23/12/2024

While submitting your quotation, the following procedure may please be observed and other points borne in mind.

1. The maker's name must be specified.
2. The "Terms and Conditions" for supply and delivery of stores, should be clearly indicated in the quotation, stating whether rates are, inclusive of all taxes, Packing and forwarding charges Freight charges, etc. or not, however rates offered as including all taxes will be more welcome.
3. If packing and forwarding charges are to be charged separately, it should be so clearly stated in your quotation.
4. Please mention clearly whether consignment would be Ex-Godown, Ex-Shop, of F.O.R. dispatching stations. Preferably terms offered as "Delivery of consignment of stores, on F.O.R."
5. Envelope should be clearly marked with our reference No and date of this quotation. It should also be superscripted as per the format given above.
6. The quotation would be opened as per date and timing given above, if desired by you, you may depute an authorized representative with a letter of authority to be present at the time of opening of the quotation at this Office on the aforesaid day, date & time.
7. Your quotation must be valid for a minimum 30 (Thirty) working days from the date of its opening.
8. Quotation received after the date of opening may not be taken into consideration.
9. Items tendered should confirm to the specification shown in the attached list when and where, full or no specifications are indicated against items in the list. Kindly furnish your full specification in accordance with accepted standards against each item tendered. Where reference to catalogue is made, the relevant catalogues/ Pamphlets/ Literature should accompany the quotation.
10. Your quotation should be for all new items and not for second hand.
11. Please state whether items will be available Ex-Stock. If not the minimum period for delivery, or for supplying the items or stores.
12. It should be clearly stated whether **GST**, Insurance, Freight or packing and forwarding charges, or any other taxes and duties, etc. leviable
13. It would be appreciated if illustrated catalogues/Literature etc. is furnished with the quotation.

14. Expression to as "Complete with standard Equipment" complete with standard accessories "Equipment to" As good as should be avoided. If at all their use is unavoidable then it should be very specifically indicated as to what exactly they mean and what exactly would be supplied under them. Any ambiguity or vagueness should be avoided.
15. A Declaration in form I will be issued for 8% sales Tax concession for sales of scientific instruments by a registered dealer, as per Provision made, under Bombay, Sales Tax-Act-1959, vide Section 41, at entry No – 1095/37/Taxation 2, dated 22 nd September,1935. If a change in declaration in form I will be issued according to the instruction issued by the Maharashtra Govt time to time.
16. For convenience, kindly adopt while quoting the same serial Nos. as given in the list detailed below.

Thanking You.

Yours faithfully,

  
Registrar

Dr. Babasaheb Ambedkar Technological University, Lone

**List of Items**

Sr. No.	Description / Specification	Specification	Make	Approx. Qty Req.	Rate per/ Each/ Unit	Remarks
1	LED Street/ Flood light and service wire	As per Annexure-A				

## Annexure-A

Sr. No.	Description / Specification	Approx. Qty. Req.	Make	Rate per/ Each/ Unit	Cost
1	<p><b>LED Street/Food Light :-</b></p> <ol style="list-style-type: none"> <li>1. Material Aluminum.</li> <li>2. Finish types: - powder coated.</li> <li>3. Shade color: - White.</li> <li>4. Shade material crystal.</li> <li>5. Power and plug description 230V AC.</li> <li>6. No batteries included.</li> <li>7. Type of bulb LED</li> <li>8. Power Terminal</li> <li>9. Color temperature 6000 kelvin.</li> <li>10. Luminaries shall carry minimum 2 year warranty on site.</li> <li>11. 5KV UP surge protection.</li> <li>12. Over voltage under voltage protection.</li> <li>13. 100% water proof.</li> <li>14. LED Osram.</li> <li>15. Bureau of India standards certificate.</li> <li>16. Protections IP65.</li> <li>17. System efficiency shall not be less than 90 lumens/ watt.</li> <li>18. CRI shall be more than 70.</li> <li>19. Total harmonic distortion voltage and current shall less than 10%.</li> <li>20. Operating voltage range shall be in range of 160V to 270V.</li> <li>21. Power factor of luminaire shall be more than 0.95.</li> <li>22. Luminaire shall conform to respective is BIS certificate.</li> <li>23. Luminaire shall withstand surge protection up to 3 KV.</li> <li>24. Correlated color temperature (CCT) shall be required between 6500 k.</li> <li>25. There shall be provision for termination of earth connection.</li> </ol>	<p>50Watts (60 Nos)</p> <p>100 Watts (40Nos)</p> <p>200 watts (12 Nos)</p>	<p>Osram, Philips, Surya, Crompton</p>		
2.	<b>4Sqmm , 2 Cre Core Aluminum Service wire</b>	600 Meter	<p>Polycab ISI mark</p>		